



Certificate No.: 1607-6526

Applicant for Certification: Ticom GmbH, Bachstrasse 41, CH- 8912 Obfelden

from: 07.04.2016

In accordance with our regulation ZW 101 „general terms and conditions of the SGWA certification body water“ the SGWA certify the following serial products:

Rubric: Stop Cocks

Denomination: TICOSAN motorized ball valves with electric actuator

Types: 2-way standard:

770.0221.000, -0321.000, -0421.000, -0521.000, -0621.000, -0721.000

3-way horizontal L-bore:

770.0224.000, -0324.000, -0424.000, -0524.000, -0624.000, -0724.000

3-way horizontal T-bore:

770.0226.000, -0326.000, -0426.000, -0526.000, -0626.000, -0726.000

Certification Standard: DN: 1/2"..." PN: 16 tmax= 65°C
SGWA ZW 126 (01/16), EN 13828

Validity: 30.09.2021

Notes / Conditions:
acoustic group: I / II

The applicant is entitled to offer the above mentioned products as certificated by the SGWA and to use the above SGWA-conformity mark (publication in the list of certificates water).



accredited according to
SN EN ISO/IEC 17065

Swiss Gas and Water Industry Association
Certification body water


Javier Fernandez
Head

Rubric: Stop Cocks

Denomination: TICOSAN motorized ball valves with electric actuator

Types	DN	PN	C°	Acoustic group	Losses	Content Index	Metrological class
2-way standard:							
770.0221.000	1/2", 15	16	65	I			
770.0321.000	3/4", 20	16	65	I			
770.0421.000	1", 25	16	65	I			
770.0521.000	1 1/4", 32	16	65	I			
770.0621.000	1 1/2", 40	16	65	-			
770.0721.000	2", 50	16	65	-			
3-way horizontal L-bore:							
770.0224.000	1/2", 15	16	65	II			
770.0324.000	3/4", 20	16	65	II			
770.0424.000	1", 25	16	65	II			
770.0524.000	1 1/4", 32	16	65	II			
770.0624.000	1 1/2", 40	16	65	-			
770.0724.000	2", 50	16	65	-			
3-way horizontal T-bore:							
770.0226.000	1/2", 15	16	65	II			
770.0326.000	3/4", 20	16	65	II			
770.0426.000	1", 25	16	65	II			
770.0526.000	1 1/4", 32	16	65	II			
770.0626.000	1 1/2", 40	16	65	-			
770.0726.000	2", 50	16	65	-			